

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7125-0569:0123

Page 1 of 1

**CATEGORY:** 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

**LISTEE:** Gentex Corporation 10985 Chicago Drive, Zeeland, MI 49464  
Contact: Keiffer Sestric (616) 392-7195 Fax (616) 392-4219  
Email: keiffer.sestric@gentex.com

**DESIGN:** Models ST24-15, ST24-15/75, ST24-30, ST24-60, ST24-75, ST24-110, GES24-15, GES24-15/75, GES24-30, GES24-60, GES24-75, GES24-110, GES24-177, and GES3-24 strobe lights; followed by suffix -W (wall mount), followed by -W or -R (white or red). Intended for indoor use and wall mount only. Model GCS-24 strobe light; followed by W or R (white or red color) and P (plain). For indoor use on wall or ceiling mount. Model AVSM Sync Module intended for indoor use with Gentex synchronizable strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Candela: 15cd, 15cd & 75cd at 00 angle axis  
30cd, 60cd, 75cd, 110cd, 177cd.  
Model GCS24: Selectable 15cd, 30cd, 75cd, 95cd, 115cd, and \*150cd.  
Model GES3-24: Selectable 15cd, 30cd, 60cd, 75cd and 110cd.  
Electrical: 21-30 VDC  
Model AVSM: 8-33 VDC/VFWR  
Flash Rate: 60 flashes per minute

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical and candela ratings and UL label.

**APPROVAL:** Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

\*Rev. 09-03-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **September 26, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
*Fire Engineering Division*