

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0569:0139

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Gentex Corporation 10985 Chicago Drive, Zeeland, MI 49464
Contact: Keiffer Sestric (616) 392-7195 Fax (616) 392-4219
Email: keiffer.sestric@gentex.com

DESIGN: Models GB6-24, GB10-24 and GB10-120* fire bells. Model GB6-24 has a 6 inch bell, Models GB10-24, -120* have 10 inch bells. Suitable for outdoor use when used with water resistant mounting box. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Models GB6-24 and GB10-24 24 VDC
Model GB10-120 120 VAC*

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, date of manufacture, Identify Marking: "Fire Alarm Service" and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible fire alarm control units. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: XL: 7135-1683:0101*

*Rev. 08-06-09 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division